



DET NORSKE VERITAS

TEST STATEMENT

TEST STATEMENT NO. DNV-2004-OSL-IP-0408

This Test Statement consists of 1 pages

This is to confirm that the
ACTUATOR

with the type designation(s)
P30R1 and P30EXR1

Manufactured by
ODEN CONTROL AB
18147 Lidingö, SWEDEN

PROJECT NO.: **42035387**

Is tested and found to comply with
IEC/EN 60529

THE ACTUATOR P30R1 AND P30EXR1 SATISFY THE REQUIREMENTS FOR IP68.
IPX8: 2 bar pressure for 10 hours.

Place and date

Høvik, 04 October 2004

for DET NORSKE VERITAS CERTIFICATION AS

Line Gangeskar
Head of section



Kjetil Johansen
Project Engineer

If any person suffers loss or damage which is proved to have been caused by any negligent act or omission of Det Norske Veritas, then Det Norske Veritas shall pay compensation to such person for his proved direct loss or damage. However, the compensation shall not exceed an amount equal to ten times the fee charged for the service in question, provided that the maximum compensation shall never exceed USD 2 million. In this provision "Det Norske Veritas" shall mean the Foundation Det Norske Veritas as well as all its subsidiaries, directors, officers, employees, agents and any other acting on behalf of Det Norske Veritas.